



62.0 Microns
Ultimate Pull Down

114.8 Microns
Final Vacuum

2.0 Microns/s
Avg. Decay Rate

0:02:44
Time to Ultimate P/D

0:00:24
Time in Decay

0:03:09
Total Elapsed Time

Customer

Cornel Opris
3650 Coral Springs Dr.
Coral Springs, Florida 33065
Cornel@accutools.com

Equipment

Make: Rheem
Model: RANL036LOAB
Serial: 18482831

Other Stats

	Values
Avg. Ambient Temp:	74.7°F
Device Name:	Emulator
Date:	1/17/2018
Start Time:	8:18:52 AM
End Time:	8:22:01 AM